

MSC.1/Circ.1275/Corr.1

31 March 2017

UNIFIED INTERPRETATION OF SOLAS CHAPTER II-2 ON THE NUMBER AND ARRANGEMENT OF PORTABLE FIRE EXTINGUISHERS ON BOARD SHIPS

Corrigendum

In the table of the annex, the words "No point if space is more than 20m walking distance from an extinguisher at each deck level" are replaced with the words "Space not more than 20m apart on both sides of the space at each deck level in each hold or compartment where vehicles are carried".
